



NOTES:-

1. ROCK LINING SHALL BE COMPRISED OF ANGULAR ROCK OF WHICH AT LEAST 75% HAS A MINIMUM MAJOR DIMENSION OF 200.
2. PROPRIETARY REVETMENT SLABS MAY REPLACE ROCK AS LINING.
3. WHERE SURFACE DRAINS ARE UNLINED, THEY SHALL BE TOP SOILED AND GRASSED.
4. CLASS 'B' GEOTEXTILE TO BE USED WHERE DRAINS ARE ROCK LINED.

		DRAFTING		DESIGN		DEPARTMENT OF INFRASTRUCTURE, ENERGY AND RESOURCES, TASMANIA	
No.	AMENDMENTS	CHECKED	DATE	APPROVED	DATE ACCEPTED	OPEN DRAINS	
1						FROM LINK NO. / DISTANCE TO LINK NO. / DISTANCE	
2	BATTER DRAINS ADDED		6/95	C.K.R.		CONTRACT NO.	
3	GEOTEXTILE ADDED		7/94	R.W.		SHEET NO.	
				R. WILSON	20/12/91	DRG. NO. 3401-3/P18-2	