



- NOTES**
1. Grade N25 concrete.
  2. Pits deeper than 1200 and less than 2400 to be fitted with step irons. Pits deeper than 2400 to be fitted with ladder.
  3. All reo. to be lapped 300 and to have 50 min. cover.
  4. All external corners to have a. 20 chamfer.
  5. Check pit dimensions fit selected grate.

DRAWING		DESIGN		DEPARTMENT OF INFRASTRUCTURE, ENERGY AND RESOURCES, TASMANIA	
NO.	DATE	DATE	DATE	PROJECT	SHEET NO.
1	8/4/98	DEC 91	DEC 91	GRATED PIT WITH DEFLECTOR MOUNTABLE KERB M1	3402-9/P29-1
DRAWN: S.J.U.		DESIGNED: R.R.W.		FROM LINK NO. / DISTANCE TO LINK NO. / DISTANCE	
CHECKED: D.Pearce		RECOMMENDED/CHECKED: J.R.G.		CONTRACT NO. / SHEET NO.	
APPROVED: J.R.G.		DATE ACCEPTED: DEC 91		3402-9/P29-1	
AMENDMENTS		DATE		DESCRIPTION	
1	8/4/98	J.R.G.	DEC 91	Pit dimensions, lintel & reo amended	