



- NOTES
1. All req. to be lapped 300 and to have 50 min. cover, 30 min cover for lid and in vicinity of deflection unit.
 2. All external corners to have a 20 chamfer.
 3. Grade N25 concrete.
 4. Pits deeper than 1200 and less than 2400 to be fitted with step irons. Pits deeper than 2400 to be fitted with ladder.
 5. Pit covers to match finished surface slope.

DRAFTING		DESIGN		DEPARTMENT OF INFRASTRUCTURE, ENERGY AND RESOURCES, TASMANIA			
NO.	AMENDMENTS	DATE	APPROVED	DATE	APPROVED	DATE	APPROVED
1			JRG		JRG		
2		31/3/98	JRG		JRG		
3	Reinforcement requirement amended		JRG		JRG		
DRAWN		DATE DESIGNED	CHECKED	DATE RECOMMENDED/CHECKED	DATE	DATE	DATE
S.J.U.		DEC91	D.Petrie	DEC'91	DEC'91	DEC'91	DEC'91
CHECKED		DATE	APPROVED	DATE	APPROVED	DATE	APPROVED
D.Petrie		DEC'91	JRG	DEC'91	R.Wilson	DEC'91	DM
DRAWING NO.		CONTRACT NO.	SHEET NO.		FROM LINK NO. / DISTANCE TO LINK NO. / DISTANCE		
3402-9/P24-4							